acenti®

Single Pole (One location) or 3-Way (Multi-location)

Fluorescent Dimmer (Lighted)

Cat. No. ATX10-1L. 1000VA

120VAC, 60Hz

For use with Mark 10[®] Powerline and Tu-Wire[®] dimmable ballasts

WARNINGS AND CAUTIONS:

- To be installed and/or used in accordance with appropriate electrical codes and regulations.
- If you are unsure about any part of these instructions, consult a gualified electrician.
- To avoid overheating and possible damage to this device and other equipment, use only with the appropriate Advance Transformer 120V Mark 10[®] Powerline or Lutron Tu-Wire[®] electronic ballasts for controlling the specific fluorescent lamps.
- When retrofitting Mark 10[®] Powerline dimming ballasts into fixtures that originally had Instant Start ballasts, the sockets MUST be replaced with Rapid Start sockets to allow proper dimmer operation and prevent damage to the dimmer ballast. Refer to the instructions provided with the ballast.
- Acenti[®] dimmers are not compatible with standard 3-way or 4-way switches. They must be used with compatible Acenti[®] remotes for multi-location dimming.
- Use only one (1) Acenti® dimmer in a multi-location circuit with up to 9 coordinating remotes without LEDs or up to 4 matching remotes with LEDs. The remote(s) will turn the light on at the brightness level selected at the dimmer.

Tools needed to install your Dimmer:

	ectrical Tape ncil Ier
--	------------------------------

MAXIMUM BULB WATTAGE

Mark 10[®] Powerline dimmers are rated in Volt-Amps (VA). The maximum bulb wattage is determined by the efficiency of the Mark 10[®] Powerline ballast. The following table shows the maximum number of ballasts that can be connected to a single dimmer for different Mark 10[™] Powerline ballasts. Also note that the table shows maximum ballasts for multi-gang installations.

Lutron Tu-Wire®:

To determine total ballast load, add the line current found on the ballast label for all ballasts in the circuit. This will indicate the total load for the control

INSTALLING YOUR DIMMER

NOTE: Use check boxes \checkmark when Steps are completed.

Cat. No. ATX10-1, 120V, For use with Advance Transformer 120V Mark 10[™] Powerline Electronic Ballasts


Advance Mark 10™	rk 10 TM		Ballasts/Dim Multi-gang	mer for	$\left \right $
Powerline Part No.	Lamp	Single Gang	Two Ganged	More than 2 Gang	
REZ-2Q18-M2-LD	CFM18W/GX24Q	23	18	15	
REZ-1T32	CFM26W/GX24Q	32	25	20	1
REZ-2Q26	CFM26W/GX24Q	17	13	11	1 [
REZ-1T32	CFM32W/GX24Q	26	20	16	ľ
REZ-1T42	CFM42W/GX24Q	20	16	13	1
REZ-1Q18-M2-BS	CFQ18W/G24Q	46	37	30	1
REZ-1Q18-M2-LD	CFQ18W/G24Q	46	37	30	
REZ-2Q18-M2-BS	CFQ18W/G24Q	23	18	15	
REZ-1T32	CFQ26W/G24Q	32	25	20	1
REZ-1T42-M2-BS	CFQ26W/G24Q	32	25	20	1
REZ-1T42-M2-LD	CFQ26W/G24Q	32	25	20	۱.
REZ-2Q26	CFQ26W/G24Q	17	13	11	1
REZ-2Q26-M2-BS	CFQ26W/G24Q	17	13	11	1 ī
REZ-2Q26-M2-LD	CFQ26W/G24Q	17	13	11	11
REZ-1Q18-M2-BS	CFTR18W/GX24Q	46	37	30	1
REZ-1Q18-M2-LD	CFTR18W/GX24Q	46	37	30	1
REZ-2Q18-M2-BS	CFTR18W/GX24Q	23	18	15	1
REZ-2Q18-M2-LD	CFTR18W/GX24Q	23	18	15	1
REZ-1T42-M2-BS	CFTR26W/GX24Q	32	25	20	1
REZ-1T42-M2-LD	CFTR26W/GX24Q	32	25	20	1
REZ-2Q26-M2-BS	CFTR26W/GX24Q	17	13	11	1
REZ-2Q26-M2-LD	CFTR26W/GX24Q	17	13	11	
REZ-1T42-M2-BS	CFTR32W/GX24Q	26	20	16	
REZ-1T42-M2-LD	CFTR32W/GX24Q	26	20	16	
REZ-2T42-M3-BS	CFTR32W/GX24Q	13	10	8	

Installing Dimmer by itself or with other devices:

If installing Dimmer in a single device application, proceed with the **INSTALLING YOUR DIMMER** section. If installing Dimmer in a multi-device application, proceed as follows:

MULTI-DEVICE APPLICATION


In multi-dimmer installations, the reduction of the dimmer's capacity is required. Refer to the chart for maximum load per dimmer.




MAXIMUM LOAD PER DIMMER FOR MULTI-DEVICE INSTALLATION

Cat. No.	Single	Two Devices	More than 2 Devices
ATX10	1000VA (8.3 A)	800VA (6.6 A)	650VA (5.4 A)

WARNING: TO AVOID FIRE SHOCK OR DEATH; TURN tep 1 OFF POWER at circuit breaker or fuse and test that power



Identifying your wiring application (most common):



Single Pole 1. Line (Hot) 2. Neutral

3. Ground 4. Load



5. Second Traveler - note color. **NOTE:** For matching remote w/LEDs installation, the First Traveler becomes Line Hot.

NOTE: If the wiring in your wall box does not resemble any of these configurations, consult a qualified electrician.

INSTALLATION INSTRUCTIONS WARNINGS AND CAUTIONS:

Lamps must be burned in at full intensity for 100 hours prior to dimming for proper dimming performance.


- · For new installations, wire a test switch before installing dimmer.
- Total minimum load must exceed 40W.
- · Dimmer may feel warm to the touch during normal operation.
- · Recommended minimum wall box depth is 2-1/2".
- Maximum wire length from dimmer to all installed remotes cannot exceed 300 ft (90 m).
- · Disconnect power at circuit breaker or fuse when servicing, installing or removing fixture.
- · Use this device only with copper or copper clad wire. With aluminum wire use only devices marked CO/ALR or CU/AL.


Step 2 cont'd

IMPORTANT : For 3-Way applications, note that one of the screw terminals Alignment Plate Held By from the old switch being removed will usually be a different color (Black) or labeled Common. Tag that wire with electrical tape and identify as the common (Line or Load) in both the dimmer wall box and remote wall box.




Pull off pre-cut insulation from dimmer leads. Make sure that the ends of the wires from the wall box are straight (cut if necessary). Remove insulation from each wire in the wall box as shown:







Strip Gage (measure bare



WIRING DIMMER:

- · Proceed to Step 6.





- For non-standard wiring applications, refer to Wire Nut and Connector Size Chart WIRE CONNECTOR / # OF COND. COMBINATION CHART

1 - #12 w/ 1 to 3 #14, #16 or #18
2 - #12 w/ 1 or 2 #16 or #18
1 - #14 w/ 1 to 4 #16 or #18
2 - #14 w/ 1 to 3 #16 or #18

Installing your Alignment Plate: Step 4

Important Notice for Installer

To achieve proper aesthetic installation of the Acenti® products, the wall surface surrounding the wall box opening must be fairly flat and free of irregularities. The wall box must be level and recessed or flush to the wall surface. The Acenti® installation system allows for adjustments that will correct minor flaws that may be present in the installation area.


This device must be installed with the Acenti[®] Alignment Plate. The Alignment Plate is packaged with the Acenti® Wallplate, which is sold separately from this device.

The Alignment Plate will function properly only if it is mounted to a flat wall surface as described above.

- · Leviton recommends to temporarily position the Alignment Plate prior to wiring the device. If the wall box wires extend at least 6 inches out of the wall box, it is also possible to install the Alignment Plate after the device has been wired (refer to Wallplate instruction sheet).
- The Alignment Plate must be installed with the tab towards the bottom. Yellow/Red wire should have Red insulation label affixed.
- · Leviton recommends the following 3 methods to temporarily hold the Alignment Plate - use of device mounting screw, use of wall box wires, or use of electrical tape (refer to the following figures):


Step 4 cont'd

· For Single-Pole Application, go to Step 5a.





DI-000-ATX10-02A



NOTE: The dimmer must be installed in a wall box that has a Load connection. The matching remote must be installed in a wall box with a Line Hot connection and a Neutral connection. A Neutral wire to the matching remote needs to be added as shown.

If you are unsure about any part of these instructions, consult a qualified electrician.

NOTE: Maximum wire length from dimmer to all installed remotes cannot exceed 300 ft (90 m).

WIRING MATCHING REMOTE (wall box with line hot connection):

Connect wires per WIRING DIAGRAM as follows:

- Green or bare copper wire in wall box to Green terminal screw. Line Hot (common) wall box wire identified (tagged) when removing old switch and First Traveler to Remote terminal marked BK.
- Second Traveler wall box wire from dimmer to remote terminal screw marked "YL/RD" (note wire color). This traveler from the remote must go to Yellow/Red dimmer lead.

Line Neutral wall box to remote terminal screw marked "WH". WIRING DIMMER (wall box with load connection):

Connect wires per WIRING DIAGRAM as follows: Green or bare copper wire in wall box to Green dimmer lead.

- Load wall box wire identified (tagged) when removing old switch to Red dimmer lead.
- First Traveler Line Hot to Black dimmer lead.
- Remove Red insulating label from Yellow/Red dimmer lead. Second Traveler wall box wire (note color as above) to Yellow/Red dimmer lead. This traveler from the dimmer must go to
- the terminal screw on the remote marked "YL/RD". Line neutral wall box wire to White dimmer lead.
- Proceed to Step 6.

Step 6 Testing your Dimmer prior to mounting in wall box:

Wall Surface

Alignment Pin (2 places) Mounting Screw (remove if applicable)

Alignment Hole (2 places)

Mounting Screw (2 places)

- If Alignment Plate is temporarily positioned using screw as in Step 4A, remove screw.
- Position all wires to provide room in outlet wall box for device.
- Ensure that the word "TOP" is facing up on the device strap.
- Partially screw in mounting screws in wall box mounting holes.

NOTE: Dress wires with a bend as shown in diagram in order to relieve stress when mounting device.

- Restore power at circuit breaker or fuse.
- See applicable operation section to ensure dimmer or switch is functioning properly.

If lights do not turn ON, refer to the TROUBLESHOOTING section.

Step 7 Remote Mounting:

To complete the Acenti® Dimmer and Wallplate installation, please refer to the instructions included with the Acenti® Wallplate and Alignment Plate.

OPERATION

NOTE: The locator light will illuminate when the load is in the OFF position to facilitate access in the dark. **NOTE:** If using the dimmer in a 3-way application, the

lights will turn ON at brightness set on dimmer's DIM/BRIGHT bar. The lighting can be controlled from either the dimmer or the remote location.

Push Pad (Default settings)

Turn ON from OFF position:

Tap - Lights turn ON to preset level.

Press and Hold – Lights turn ON to full bright.

Turn OFF from ON position: Tap - Lights turn OFF.

DIM/BRIGHT Bar

BRIGHTEN:

Press the right half of the DIM/BRIGHT Bar - Lights brighten to desired level.

DIM: Press left half of DIM/BRIGHT Bar -Lights dim to desired level.

If you continue to hold, the lights will DIM to minimum level and then turn OFF. NOTE: The turn on light level can be changed

when lights are off by using the DIM/BRIGHT Bar. If there is a power outage, when the power is restored, the lights will

return to the last setting before the power interruption.

Air-Gap Switch: On the dimmer only, gently pull the bottom of the push pad forward until it lifts off the strap to engage the air-gap switch. This will cut power to the fixture to replace the bulb. After servicing is complete, to return push pad back to neutral position disengage the push pad holder by pressing on push pad holder with index finger while pushing the push pad back into the neutral position (refer to OPERATION figure 3).

Gently lift bottom of push pad out

NOTE: This device has a removable push pad. If there is a need to re-install the push pad, proceed as follows:

- Line up tabs located on top back of pad with openings in the top of strap and gently press in. Line up tab located on bottom back of pad with
- opening in the bottom of strap and gently press in. · Press up on push pad holder while pushing in push pad to re-engage.

Cleaning: Clean with a damp cloth. DO NOT use chemical cleaners.

ADVANCED PROGRAMMING FEATURES

Definition of A Modes

- A-1) Energy Save: Sets the maximum brightness level for energy savings.
- A-2) Minimum Brightness Level: Sets the minimum dimming level.
- A-3) Preset ON Level: Sets the turn on brightness level regardless of the previous set light level (formerly Dim Lock).
- A-4) Almost OFF Level: Sets the brightness level the device will dim to A-4) when the push pad is pressed to turn off. In this mode the lights will always remain on.

Definition of B Modes

- B-1) ON Fade Rate: Sets the amount of time in seconds it takes the lights to turn ON to maximum brightness.
- B-2) OFF Fade Rate: Sets the amount of time in seconds it takes the lights to turn OFF from maximum brightness.
- B-3) LED Options: Sets the time period in seconds the Locator LED and Brightness display will stay on before extinguishing.

Definition of C Modes

C) Restore Defaults: Restores the factory default settings.

Definition of LEDs Leftmost LED = LED 1 Rightmost LED = LED 7

NOTES:

- The device will exit programming mode after 3 minutes of inactivity
- Pressing the Push Pad at any time during programming will advance the device to the next programming mode.

Program Mode A

To enter Program Mode A:

Press and hold the Push Pad and then the *right* half of the DIM/BRIGHT Bar (^) for 5 seconds until the Locator LED and leftmost LED (LED 1) begin to blink.

A-1) Upon releasing the Push Pad and the *right* half of the DIM/BRIGHT Bar (^), the Locator LED will continue to blink once per second and the rightmost LED will illuminate to display the device is in Program Mode A-1, Energy Save. The default energy save mode is 100% i.e. full bright. To change the Energy Save level, use the DIM/BRIGHT Bar to move the corresponding LED to the desired discrete preset level according to Chart A. By tapping the Push Pad this setting will automatically be saved and the device will advance to the next programming mode, A-2.

Chart A

When indicator light is at LED #	Light output is at	Energy consumption savings amounts to
7	100%	0%
6	97%	5%
5	95%	8%
4	90%	11%
3	85%	14%
2	80%	17%
1	75%	20%

A-2) The Locator LED will blink 2 times per second to indicate the device is in Program Mode A-2, Minimum Brightness Level. The default Minimum Brightness Level is approximately 20%. To change the Minimum Brightness Level from 1-50%, use the DIM/BRIGHT Bar. The light output will reflect the minimum brightness level selected. By tapping the Push Pad this setting will automatically be saved and the device will advance to the next programming mode. A-3.

- A-3) The Locator LED will blink 3 times per second to indicate Program Mode A-3, Preset ON Level. To change the current Preset ON Level from 1-100%, use the DIM/BRIGHT Bar. If this feature is not desired, press and hold the left half of the DIM/BRIGHT Bar (v) until no LED is lit (default setting). By tapping the Push Pad this setting will automatically be saved and the device will advance to the next programming mode, Δ-4
 - The Locator LED will blink 4 times per second to indicate Program Mode A-4, Almost OFF Level. To change the current Almost OFF Level, use the DIM/BRIGHT Bar to adjust the preset light level. If this feature is not desired, press and hold the *right* half of the DIM/BRIGHT Bar (A) until no LED is lit (default setting). By tapping the Push Pad this setting will automatically be saved and the device will exit Programming Mode A. Almost OFF can be overridden by pressing and holding the left half of the DIM/BRIGHT Bar (\mathbf{v}) until lights turn off.

NOTE: When Almost OFF Level is set the LED Locator will be illuminated when the dimmer is in the Almost OFF state, even though the light remains on.

Program Mode B To enter Program Mode B:

1234567

LED Brightness

Display

Press and hold the Push Pad and then the left half of the DIM/BRIGHT Bar (\mathbf{v}) for 5 seconds until the Locator LED and rightmost LED (LED 7) begins to blink.

- B-1) Upon releasing the Push Pad and the left half of the DIM/BRIGHT Bar (\mathbf{v}) , the Locator LED will continue to blink once per second indicating he dimmer is in Program Mode B-1, ON Fade Rate. To change the ON Fade Rate, use the DIM/BRIGHT Bar to move the LED to the desired preset level according to Chart B. By tapping the Push Pad this setting will automatically be saved and the device will advance to the next programming mode, B-2.
- B-2) The Locator LED will blink 2 times per second to indicate Program Mode B-2, OFF Fade Rate. To change the OFF Fade Rate, use the DIM/BRIGHT Bar to move the LED to the desired preset level according to the Chart B. By tapping the Push Pad this setting will automatically be saved and the device will advance to the next programming mode, B-3. Chart B

	Chart B	
LED	FADE ON	FADE C
LED 1	0 seconds (instant)	0 seconds (
LED 2 (Default)	0.5 seconds	0.5 seconds
LED 3	1.5 seconds	1.5 seconds
LED 4	3.0 seconds	3.0 seconds
LED 5	6.0 seconds	6.0 seconds
LED 6	10 seconds	10 seconds
LED 7	25 seconds	25 seconds

B-3) The Locator LED will blink 3 times per second to indicate Program Mode B-3, LED Options. To change the LED Options settings, use the DIM/BRIGHT Bar to move the LED to the desired preset setting according to **Chart B-3**. By tapping the Push Pad this setting will automatically be saved and the device will exit Programming Mode B. Chart B-3

LED	LOCATOR LED TIMEOUT	LED BRIGHTNESS DISPLA
LED 1	Active	Active
LED 2	Active	Turns off 5 sec. after
LED 3	Turns off 5 sec. after use	Active
LED 4	Turns off 5 sec. after use	Turns off 5 sec. after
LED 5	N/A	N/A
LED 6	N/A	N/A
LED 7	N/A	N/A

LIMITED 5 YEAR WARRANTY AND EXCLUSIONS

Leviton warrants to the original consumer purchaser and not for the benefit of anyone else that this product as the time of its sale by Leviton's only obligation is to correct such defects by repair or replacement, at its option, if within such five year period the product is returned prepaid, with proof of purchase date, and a description of the problem to Leviton Manufacturing Co., Inc., Att: Quality Assurance Department, 59-25 Little Neck, New York 11362-2591. This warranty is void if this product is installed improperly or in an improper environment, overloaded, misused, opened, abused, or altered in any manner, or is not used under normal operating conditions or not in accordance with any labels or instructions. There are no other or implied warranty is required by the applicable jurisdiction, the duration of any such implied warranty and fitness for a particular purpose, but if any implied warranty is required by the applicable jurisdiction. for a particular purpose, is limited to five years. Leviton is not liable for incidental, indirect, special, or consequential damages, including without limitation, damage to, or loss of use of, any equipment, lost sales or profits or delay or failure to perform this warranty obligation. The remedies provided herein are the exclusive remedies under this warranty.




Fig. 3

Push up

holder


and

press

push

pad in

←(2)



100

I FD

Locator

Light





